

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 408

Dated: 07/02/2026

It is certified that an inspection team headed by Naveen Kumar R

(Name of Officers with designation) from Assistant Executive Engineer, PHED, RDWSD, Arkalgud

inspected the Christa Jyothi School, Kellur, H.N.Purna Rd, Arkalgud

(Name & Address of the school) on(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated 30/01/2026

of Distric Water Testing Laboratory, Hassan, RDWSSD (PHED Lab) certified that the


Christa Jyothi School, Arkalgud (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30/06/2026

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department : RDWSD, Arkalgud

To Christ Jyothi School
Kellur, H.N.Purna Rd, Arkalgud
(Name & Address of the Institution)

**Assistant Executive Engineer
Rural Drinking Water Supply
And Sanitation Department
Arkalgud Sub Division, Arkalgud**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ
ಜಿಲ್ಲಾ ಕುಡಿಯುವ ನೀರು ಪರೀಕ್ಷಾ ಪ್ರಯೋಗಾಲಯ, ಹಾಸನ

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರವರ ಕಛೇರಿ, ಗ್ರಾಮೀಣ
ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ,
ಹಾಸನ ವಿಭಾಗ, ಹಾಸನ 573201

eerdwsd.hsn@gmail.com
rdwsd.wqmsh.hassanlab@gmail.com
Phone No.08172-261640

WATER SAMPLE TEST REPORT


1.District :	Hassan	5.Sample collection date:	27.01.2026
2.Taluk:	Arkalgudu	6.Sample received date:	27.01.2026
3.Village:	Kelluru	7.Source:	Filter Water
4.Grama Panchayath:	-	8.Name and address:	Christa Jyothi School, Kelluru village, Arkalgudu Taluk, Hassan District.

Sl.No	Characteristic	Requirement (Acceptable limit)	Permissible Limit in the Absence of Alternate Source	Method of Test,Ref to	Result
1	Colour,Hazen units	5	15	IS 3025(Part-4):2021	1
2	Odour	Agreeable	Agreeable	IS 3025(Part -5 &6):2018	Agreeable
3	Ph, Value	6.5-8.5	No Relaxation	IS 3025 (Part-11):2022	6.52
4	Turbidity, NTU	1	5	IS 3025 (Part -10):2023	1
5	Total Dissolved solid, mg/l	500	2000	IS 3025 (Part -16):2023	22
6	Conductivity us/cm	-	-	IS 3025 (Part -14):2019	37.2
7	Calcium(as Ca) mg/l	75	200	IS 3025 (Part- 40):2024	<8
8	Chloride (as Cl) mg/l	250	1000	IS 3025 (Part -32):1988	<10
9	Fluoride (as F)mg/l	1	1.5	APHA 24th Edition:4500 F-D	<0.1
10	Iron (as Fe)mg/l	1	No Relaxation	IS 3025 (Part -53):2024	<0.1
11	Magnesium (as Mg) mg/l	30	100	IS 3025 (Part -46):2023	<5
12	Nitrate (as NO3) mg/l	45	No Relaxation	APHA 24th Edition:4500 NO3-B	<0.5
13	Sulphate (as SO4) mg/l	200	400	IS 3025 (Part -24/sec 1):2022	<1
14	Total Alkalinity mg/l	200	600	IS 3025 (Part -23):2023	8
15	Total Hardness (as CaCO3)mg/l	200	600	IS 3025 (Part -21):2009	<20

Inference:The analyzed values for the above parameters are within the limit as per IS-10500:2012.

Date:30.01.2026
Place: Hassan




Chemist
District Water Testing Laboratory
R.D.W.& S D Hassan.